

§ 250.459

(b) You must record the daily inventories of drilling fluid and drilling fluid materials, including weight materials and additives in the drilling fluid report.

(c) If you do not have sufficient quantities of drilling fluid and drilling fluid material to maintain well control, you must suspend drilling operations.

§ 250.459 What are the safety requirements for drilling fluid-handling areas?

You must classify drilling fluid-handling areas according to API RP 500, Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities, Classified as Class I, Division 1 and Division 2 (as incorporated by reference in § 250.198); or API RP 505, Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities, Classified as Class 1, Zone 0, Zone 1, and Zone 2 (as incorporated by reference in § 250.198). In areas where dangerous concentrations of combustible gas may accumulate, you must install and maintain a ventilation system and gas monitors. Drilling fluid-handling areas must have the following safety equipment:

(a) A ventilation system capable of replacing the air once every 5 minutes or 1.0 cubic feet of air-volume flow per minute, per square foot of area, whichever is greater. In addition:

(1) If natural means provide adequate ventilation, then a mechanical ventilation system is not necessary;

(2) If a mechanical system does not run continuously, then it must activate when gas detectors indicate the presence of 1 percent or more of combustible gas by volume; and

(3) If discharges from a mechanical ventilation system may be hazardous, then you must maintain the drilling fluid-handling area at a negative pressure. You must protect the negative pressure area by using at least one of the following: a pressure-sensitive alarm, open-door alarms on each access to the area, automatic door-closing devices, air locks, or other devices approved by the District Manager;

(b) Gas detectors and alarms except in open areas where adequate ventilation is provided by natural means. You

30 CFR Ch. II (7–1–12 Edition)

must test and recalibrate gas detectors quarterly. No more than 90 days may elapse between tests;

(c) Explosion-proof or pressurized electrical equipment to prevent the ignition of explosive gases. Where you use air for pressuring equipment, you must locate the air intake outside of and as far as practicable from hazardous areas; and

(d) Alarms that activate when the mechanical ventilation system fails.

OTHER DRILLING REQUIREMENTS

§ 250.460 What are the requirements for conducting a well test?

(a) If you intend to conduct a well test, you must include your projected plans for the test with your APD (form BSEE-0123) or in an Application for Permit to Modify (APM) (form BSEE-0124). Your plans must include at least the following information:

(1) Estimated flowing and shut-in tubing pressures;

(2) Estimated flow rates and cumulative volumes;

(3) Time duration of flow, buildup, and drawdown periods;

(4) Description and rating of surface and subsurface test equipment;

(5) Schematic drawing, showing the layout of test equipment;

(6) Description of safety equipment, including gas detectors and fire-fighting equipment;

(7) Proposed methods to handle or transport produced fluids; and

(8) Description of the test procedures.

(b) You must give the District Manager at least 24-hours notice before starting a well test.

§ 250.461 What are the requirements for directional and inclination surveys?

For this subpart, BSEE classifies a well as vertical if the calculated average of inclination readings does not exceed 3 degrees from the vertical.

(a) *Survey requirements for a vertical well.* (1) You must conduct inclination surveys on each vertical well and record the results. Survey intervals may not exceed 1,000 feet during the normal course of drilling;